

ADDENDUM NO. 1

TO WHOM IT MAY CONCERN:

T-213-10
Request for Tenders
Grit System Replacement at Georgetown Wastewater
Treatment Plant

This addendum, issued Thursday, February 25, 2010, must be incorporated into and made part of the above noted Request for Tenders document.

ISSUE #1:

DELETE: SPECIAL PROVISIONS, (PAGE OF 3 OF 3) ITEM #7, INSURANCE.

REFER: TO GENERAL TERMS AND CONDITIONS (PAGE 2 OF 11), INSURANCE, ITEM #4 FOR THE REQUIRED INSURANCE NEEDED FOR THIS TENDER ONLY.

ISSUE #2:

CHANGED SCOPE OF WORK (SEE THE ATTACHED PAGES FOR COMPLETE DETAILS)

All other terms and conditions remain the same.

This addendum must be acknowledged in the submitted Tender document.



Brad Andrews, CPPB
Purchasing Analyst

**Regional Municipality of Halton
Georgetown WWTP
Grit System Replacement
Tender T-213-10**

ADDENDUM NO. 1

Issue Date: February 25, 2010

This Addendum No. 1 forms part of the Plans and Contract Documents for the above noted contract and shall be read in conjunction therewith. This Addendum No. 1 shall take precedence over all requirements of the original plans and contract documents issued previously. The Tenderer must acknowledge receipt of this Addendum on page 1 of the Pricing Summary.

NO. OF ADDENDUM PAGES:	3
NO. OF REVISED CONTRACT DOCUMENT PAGES:	0
NO. OF DRAWINGS (SKETCHES):	0
NO. OF NEW SPECIFICATION PAGES:	0
TOTAL NO. OF PAGES:	3

1. Replace Existing Section 11704 – Grit Classifiers, Clause 1.2.1 with the following:

“All degritting equipment furnished under this Section shall be of a design and manufacture that has been used in similar applications, and it shall be demonstrated to the satisfaction of the Owner that the quality is equal to equipment made by that manufacturer specifically named herein. Manufacturers shall provide evidence of at least five (5) installations in which similarly sized equipment has provided satisfactory performance for a minimum of five (5) years in a similar application. No consideration will be given to individually sized equipment that hasn't been commercially available for five (5) years.”

2. Replace Existing Section 11704 – Grit Classifiers, Clause 1.2.2 with the following:

“Documentation shall be submitted for approval showing the manufacturer's quality control program and the equipment shall not be released for shipment until approved.”

3. Add the following to Section 11704 – Grit Classifiers; Clause 2.1 Acceptable Manufacturers.

“.2 WTP Equipment Corporation.”

4. **Revise Existing Section 11320 – Horizontal Recessed Impeller Pumps, Clause 2.1 Acceptable Manufacturers to read:**

- “.1 Hayward Gordon Torus Model XR
.2 Wemco Model C”**

5. **Add the following to Existing Section 11320 – Horizontal Recessed Impeller Pumps:**

“2.9 Shaft Sealing

.1 The Inboard seal faces will be Tungsten Carbide on Silicon Carbide and the outboard faces carbon on ceramic. All seal metal parts and gland plate will be 316SS and the shaft seals Buna or better. Provision for flush and drain connections shall be provided. Pump manufacturer shall advise the amount and pressure of flush water required for each application. The contractor shall provide the necessary flushing system per the contract plans. Acceptable suppliers are Flowserve, Chesterton or John Crane.”